

From: [Susan Clewis](#)
To: [Delgado, Eric](#)
Subject: Fwd: Update 1 - Backflow Incident; R14; City of Corpus Christi; Notification of Water Sector Impact
Date: Thursday, December 15, 2016 10:21:08 PM
Attachments: [image001.png](#)

Begin forwarded message:

From: Susan Clewis <susan.clewis@tceq.texas.gov>
Date: December 15, 2016 at 7:27:39 PM CST
To: HSNotify <HSNotify@tceq.texas.gov>, WSI <WSI@tceq.texas.gov>
Subject: **Update 1 - Backflow Incident; R14; City of Corpus Christi; Notification of Water Sector Impact**

Update #1 -

Based on the report of a possible backflow incident affecting the City's public water supply, a "Do Not Use the Water" advisory was issued to the City of Corpus Christi's customers on December 14, 2016 at 10:30 pm. The City has shut-off water service to the facility where the reported backflow occurred. The suspect contaminant is an emulsifier (mixture of Indulin® AA-86, hydrochloric acid, and water).

The TCEQ Corpus Christi Region Office in partnership with the City of Corpus Christi has collected a sample of the additive (Indulin® AA-86). In addition, samples were collected in the City's drinking water distribution system. EPA is partnering with the TCEQ to analyze all samples and determine the potential impact. EPA and TCEQ are also reviewing engineering data/models of the drinking water system provided by the City to determine affected areas.

The TCEQ is currently investigating the reported backflow incident.

TCEQ Notification Type: Water Sector Impact

Notification Status: Initial

General Incident Information:

Type of Incident: Backflow

Date: December 7, 2016

Time (am/pm) Incident Started: unknown

Time (am/pm) TCEQ Notified: December 14, 2016, approximately 15:00

TCEQ Region: Region 14 Corpus Christi

Responsible Party (RP)/Regulated Entity Information/Incident Location

RP/Regulated Entity Name: City of Corpus Christi



9804983

RN Number (if available): RN101385151
Street Address: 6746 Up River Rd.
City: Corpus Christi
County: Nueces
RP Contact Name and Information: Gabriel Ramirez, 361-816-5208

Specific Incident Information

Description of Event/Cause: backflow incident from a chemical tank impacting the public water system
Material Released: Indoline/Hydrochloric Acid
Amount Released (estimated): unknown
Affected Media: Drinking water (distribution system)
Injuries or Fatalities: None noted
Other Risks: NA

Current Response

TCEQ Response: TCEQ mobilized at approximately 15:20
TCEQ Responder Name and Contact Information: Blas Rizzo 361-816-9596
Incident Commander Name and Contact Information: NA
Emergency Response Contractor Information: NA
Other Federal, State, or Local Authorities on Site: City of Corpus Christi

Other Pertinent Information, If Available

Weather: NA
Wind Direction: NA
Potentially Impacted Receptors: drinking water distribution system and surface/groundwater from flushing activities
Other: N/A

****PLEASE NOTE:** This notification is based on the initial report of a spill/release/emission event/threat or other such occurrence received by TCEQ. Since this notification may contain preliminary information, the TCEQ cannot verify the types or quantities of releases at this time and cannot make any definitive determination about the potential danger to human health or the environment as a result of this release. Specific chemicals, quantities, and the identified risk to human health and safety or environment may change as more information becomes available. TCEQ is providing the information available for the incident at the time of the notification. Staff may not have all the information requested on this Template.

Susan Clewis
Regional Director
Texas Commission on Environmental Quality
Region 14/Corpus Christi
(361)825-3104 - office

(361)533-3652 - cell
susan.clewis@tceq.texas.gov

